



PUBLIC WORKS DEPARTMENT

CITY OF PORTSMOUTH

680 Peverly Hill Road

Portsmouth N.H. 03801

(603) 427-1530 FAX (603) 427-1539

December 21, 2011

Stephanie Larson
NHDES
PO Box 95
29 Hazen Drive
Concord, NH 03301

Subject: Daily Maximum Fecal Violations
NPDES Permit No. NH0090000
Discharge No. 005A

Dear Ms. Larson:

This is the five-day follow up letter for a daily maximum fecal violation for the Pease Facility. The following conditions occurred:

Date of Sample: 12/18/11
Chlorine Residual before Dechlorination at the time of Sample: 6.9 mg/L
Chlorine Residual after Dechlorination at the time of Sample: 0.02 mg/L
Free Chlorine 0.6 mg/L
Plant Flow at time of Sample: 0.58 MGD
Fecal Results: 80/100ml

Please call if you have any questions or need additional information.

Sincerely,

Peter Rice

Cc: Joy Hilton, USEPA
Paula Anania